

Engineer M.ULAGANATHAN, M.E, M.I.E, F.I.V, M.I.C.A, M.I.I.T.A

Office: 28, Whites Road, Royapettah, Chennai – 600 014

Residential Address: 34/83, Third Floor, Mandaveli Street, Chennai - 600028

SBI Bank, panel approval: CONGELL/66 Date: 31.01.2014

Punjab National Bank, panel approval

Fellow in [FIA. StrucE – F – 358], Indian Association of Structural Engineers

Chartered Engineer: Instn of Engrs [India], Regn No: M 118935 – 7 [04.08.2000]

Approved Valuer [Category – I/515/2000- 2001] for Income Tax & Wealth Tax

Fellow Category – I, Valuer [No: F- 10187/09.03.2001] Institution of Valuers

Competent Person for Stability Certification of Factory Buildings

Class – I, Licenced Surveyor, Corporation of Chennai & CMDA

E- mail: ulaga.62@gmail.com, ulaga.1962@rediffmail.com

Mobile : 098411 58366, 9940084126 Phone: 044 2462 0158

**STRUCTURAL/ CHARTERED ENGINEERS CERTIFICATE FOR INSPECTION,
THIRD PARTY VERIFICATION FOR STRUCTURAL STABILITY &
CONFIRMATION OF STRUCTURAL STRONGNESS OF INSTITUTIONAL
BUILDING [MEASI INSTITUTE OF MANAGEMENT BUILDING] AT DOOR NO:
147[NEW], 87[OLD], PETERS ROAD, ROYAPETTAH, CHENNAI CITY, PIN CODE
: 600 014, CORPORATION WARD No: 115 BLOCK No: 27 ZONE :
09,TRIPLICANE TALUK, CHENNAI DISTRICT, TAMILNADU, INDIA**

I have inspected today [11.07.2017] the above building.

The Foundation and other structural detailed drawings of the above building were produced. On verification with the available information, it is ascertained that the building is originally designed for Ground, First & Second floor. From scrutiny the sizes of RCC columns and beams are adequate and sufficient to bear Ground plus Three Floors

The age of the Building is 35 years. The expected residual life is 45 years approximately, at proper maintenance

I herewith certify that the building structure is designed as per standard engineering practice. Framed Structure has been well designed. All RCC columns are interconnected with RCC Beams. The Floor and Roof slabs are of RCC, M 15 Grade. Weathering Course has been laid as per standard procedure. The Floor surface finish is in good serviceable condition. There was no dampness in any portion of the Building. There is no structural crack in any part of the building

I certify that the Structure of Institutional Building is **SAFE & STRONG** as in existing condition.

This Certificate is valid for next Ten years from the date of issue

This Certificate has been issued based on the AICTE approval no: F.No: Southern/1-2811586012/2016 EOA Dated 25.04.2016 & F.no: AICTE/AB/Approval Process Dated 13.10.2016



CHARTERED ENGINEER
M-118935-7/04-08-2000

Signature of the Structural Engineer & Chartered Engineer

Date 31/01/17 Place: Royapettah, Chennai - 600 014

Residential Address: 34/83, Mandaveli Street, Chennai - 600 028.

SBI Bank panel approval: CONGELL/66 Date: 31.01.2014

Fellow in [FIA, StrucE – F – 358], Indian Association of Structural Engineers.

Name & Address of the Institution with which registered:

Institution of Engineers [India], Kolkatta, Regn No: M 118935 - 7 [04.08.2000]

Central Govt. Regd. Approved Valuer [No: F 10187] for Income Tax & Wealth Tax

DIRECTOR
MEASI INSTITUTE OF MANAGEMENT
CHENNAI - 600 014.